

# County of San Diego Planning & Development Services BUILDING DIVISION

# ACCESSIBILITY CORRECTION LIST

Multifamily Housing

**3A** 

# **Curb Ramps**


| PLA                     | NN CHECK #:   | OWNE | ER ON APPLICATION:   |
|-------------------------|---|------|--|
| GEN<br>1.<br>2.         | NERAL REQUIREMENTS  Identify on site accessibility plan location of all curb ramps.  CBC 1112A  Built-up curb ramps shall not project into vehicular traffic lanes, parking stalls, or parking access aisles.  CBC 1109A.8.2(2) and CBC 1112A.2   | 11.  | Detail grooved border complying with the following per CBC Figure 11A-3C and CBC Figure 11A-3K at each curb ramp:  Located at level surface of walk along top and sides of curb ramp  12-inches (absolute) wide Grooves ¼-inch deep Grooves spaced ¾-inch on center  CBC 1112A.8   |
| 3.                      | Curb ramps shall be located or protected to prevent obstruction by parked vehicles.  CBC 1112A.2  | 12.  | Detail detectable warning complying with the following at each curb ramp:  Extending full width and depth of curb ramp run  Exception: Where pair of parallel curb ramps provided per CBC Figure 11A-3F with bottom landing outside vehicular way, minimum 36-inch-wide continuous detectable warning strip may be provided where bottom landing adjoins or enters vehicular way in lieu of detectable warning on both curb ramp runs  Slip-resistant and integral part of walking surface  Including raised truncated domes per CBC Figure 11A-3N:  0.9-inch base diameter tapering to 0.45-inch top diameter  0.2-inch height  2.35-inch center-to-center spacing  Visual contrast with adjoining surfaces, light on dark or dark on light, with contrast material an integral part of walking surface  CBC 1112A.9  Specify the following for transitions from curb ramps to adjoining walks, gutters, and streets:  Flush and free of abrupt change  Maximum 1:20 slope (5% gradient) of adjoining walks, gutters, |
| DIM<br>4.               | ENSIONS AND SLOPES  Provide complete dimensions and coordinated detailing for each curb ramp.  CBC 1112A  |      |  |
| 5.                      | Dimension minimum 48-inch width – lying in a single-sloped plane – of each curb ramp run.  CBC 1112A.3 and CBC 1112A.5  |      |  |
| 6.                      | Specify running slope of each curb ramp run.  CBC 1112A.5  Specify and dimension the following to verify slope(s) indicated per   |      |  |
| 7.                      | Specify and dimension the following to verify slope(s) indicated per item 6 do not exceed 1:12 (8.3% gradient) for each curb ramp run:  □ Elevations at top and bottom curb ramp landings □ Length of curb ramp run  CBC 1112A.5                  | 13.  |  |
| 8.                      | If curb ramp located where pedestrians must walk across ramp, detail flared sides on curb ramp with maximum 1:10 slope (10% gradient).  CBC 1112A.5   | 44   | and streets within 48 inches of top and bottom of curb ramp  CBC 1112A.5  Detail and dimension any diagonal/corner curb ramps to comply  |
| 9.                      | Specify surfaces of curb ramps and flared sides shall be stable, firm, slip-resistant finish contrasting with finish of adjacent walk.  CBC 1112A.7   | 14.  | additionally with the following:  Minimum 48-inch clear space at bottom of ramp and within any marked crossings per CBC Figure 11A-3H  If ramps have returned curb or other well-defined edges, such edges shall be parallel to direction of pedestrian flow  If ramps have flared sides, minimum 24-inch-long segment of straight curb required on each side of ramp and within any marked crossings  CBC 1112A-4   |
| 10.                     | At top of each curb ramp, dimension minimum 48-inch-deep level landing for full curb ramp width.  Exception: Landings less than 48-inches deep allowed where flared sides of curb ramp limited to maximum 1:12 slope (8.3% gradient)  CBC 1112A.6 |      |  |
| ADDITIONAL REQUIREMENTS |   |      |  |
|                         |   |      |  |

THIS DOCUMENT IS FOR PLAN REVIEW ONLY.


CORRECTION LIST ITEMS MAY NOT BE REPRODUCED OR COPIED ON PLANS.


PROVIDE COMPLETE DETAILS, DIMENSIONS, AND NOTES TO SATISFY CORRECTION ITEMS.

PDS 627A REV.: 09/24/2012 PAGE **1** of **4** 




#### **CBC FIGURE 11A-3A - CURB DETAILS**






CBC FIGURE 11A-3B - CURB DETAIL




CBC FIGURE 11A-3D - CURB DETAIL



CBC FIGURE 11A-3E - CURB DETAIL


**CBC FIGURE 11A-3C - CURB DETAILS** 

THESE FIGURES ARE FOR ILLUSTRATIVE PURPOSES ONLY.
THEY ARE NOT INTENDED FOR REPRODUCTION AS PLAN DETAILS.
IF CONFLICTS EXIST BETWEEN THESE FIGURES AND THE TEXT
OF THE CALIFORNIA BUILDING CODE, THE CODE TEXT SHALL GOVERN.




**CBC FIGURE 11A-3F - CURB DETAIL** 


SIDEWALK LESS THAN 60" WIDE




**CBC FIGURE 11A-3G - CURB DETAIL** 




**CBC FIGURE 11A-3J - CURB DETAIL** 



CBC FIGURE 11A-3K - CURB DETAIL




**CBC FIGURE 11A-3I - CURB DETAIL** 




**CBC FIGURE 11A-3L - CURB DETAILS** 


THESE FIGURES ARE FOR ILLUSTRATIVE PURPOSES ONLY.
THEY ARE NOT INTENDED FOR REPRODUCTION AS PLAN DETAILS.
IF CONFLICTS EXIST BETWEEN THESE FIGURES AND THE TEXT
OF THE CALIFORNIA BUILDING CODE, THE CODE TEXT SHALL GOVERN.



## CBC FIGURE 11A-3M - CURB RAMPS AT MARKED CROSSINGS



### (a) TRUNCATED DOME SPACING



(b) TRUNCATED DOME SECTION A-A

## **CBC FIGURE 11A-3N - TRUNCATED DOMES**

THESE FIGURES ARE FOR ILLUSTRATIVE PURPOSES ONLY.
THEY ARE NOT INTENDED FOR REPRODUCTION AS PLAN DETAILS.
IF CONFLICTS EXIST BETWEEN THESE FIGURES AND THE TEXT
OF THE *CALIFORNIA BUILDING CODE*, THE CODE TEXT SHALL GOVERN.